



Cabuyao Water District

Main Office: 2nd Floor, Centro Mall, Brgy. Pulo, Cabuyao City, Laguna
Tel. No.: (049) 832-1620 Website: www.cabuyaowaterdistrict.com
Email: cabuyaowaterdistrict@gmail.com


Certification of Water Potability

This is to certify that the water being supplied by Cabuyao Water District to all of its concessionaires is potable and has passed the Philippine National Standard for Drinking Water, based on tests done by Alpha Laboratory Calamba Philippines Corporation, a laboratory accredited by the Department of Health, with Accreditation No. 4A-001-13-LW-2.

CABWAD has met the required limit of residual chlorine from 0.20 mg/L to 0.40 mg/L prior to distribution, with an average of 0.26mg/L for all its sampling points.

This further certifies that the samples taken from the above-mentioned areas were from January 2022 to December 2022.

Issued this 3rd day of March 2023.


ARNOLD G. VALENCIA
General Manager